

FORANE[®] 427A

THE CONVERSION FROM A COMPETITOR'S DROP-IN REFRIGERANT TO FORANE[®] 427A IN A BISCUIT FACTORY

The French company MULTI FROID SERVICES successfully carried out the replacement of a competitor's drop-in refrigerant by FORANE[®] 427A in a medium temperature refrigeration unit in a biscuit factory. The conversion took place in close cooperation with CLIMALIFE, Dehon Group, who distributes FORANE[®] refrigerants in France.

One year earlier, this unit supplying cold air to a refrigerated biscuit cooling tunnel was converted from R-22 to a competitor's drop-in with no oil change. Wishing to discontinue using any HCFCs, the customer decided to replace R-22 by this competitive product as it was a zero-ODP refrigerant. However, he very rapidly recognised important performance losses principally linked to the poor oil return of the drop-in. The evaporator had become clogged by mineral oil. He consequently asked CLIMALIFE for a better solution and decided to test FORANE[®] 427A.

The conversion took place in the spring of 2006. Very satisfactory running conditions were rapidly reached and the customer is now highly satisfied with the performance of the installation particularly during the summer period.

Unit description

The main characteristics of the converted refrigeration unit are as follows:

- 1 reciprocating semi-hermetic BITZER compressor (BHS491)
- nominal refrigerating power: 2.2 kW
- water-cooled condenser
- bladed evaporator
- thermostatic expansion valve
- refrigerant charge: 5 kg
- air temperature set point: 3°C



Retrofit procedure

Non-toxic, non-flammable and zero ODP refrigerant, FORANE[®] 427A normally requires only that the original oil be drained once and replaced by a POE lubricant. Optimal performance close to R-22 can generally be achieved without a long and costly rinsing of the circuit thanks to a high tolerance of this new FORANE[®] grade to any residual original oil. However in view of the poor performance of the competitor's drop-in due to unsatisfactory oil return and hence fouling of the evaporator, it was decided in this case to rinse the circuit once.

After ensuring that the equipment was in a good state (a defective regulation valve had to be changed) and measuring the performance of the installation with the initial refrigerant charge, the competitor's product was replaced by FORANE[®] 427A and the mineral oil was replaced by a POE lubricant (Emkarate RL32H) with one rinsing step. The installation was then restarted and FORANE[®] 427A performance measured after running conditions had reached a steady state. Only a slight adjustment of the expansion valve was necessary.

Very satisfactory running conditions were rapidly reached. The temperature set point of 3°C was easily achieved with similar energy consumption despite 10% of residual mineral oil in the circuit.

FORANE® 427A consequently fully satisfies the requirements of the European regulations while enabling existing equipment to continue to perform well without the need for any long and costly plant modifications.

The versatility of FORANE® 427A is also appreciated as it can be used to retrofit low temperature refrigeration equipment as well as air-conditioning installations, resulting in only one retrofit refrigerant for all R-22 units.

Combining environmental friendliness, high performance and simplicity is today a reality with FORANE® 427A !

The information contained in this document is based on trials carried out by our Research Centres and data selected from the literature, but shall in no event be held to constitute or imply any warranty, undertaking, express or implied commitment from our part. Our formal specifications define the limit of our commitment. No liability whatsoever can be accepted by Arkema with regard to the handling, processing or use of the product or products concerned which must in all cases be employed in accordance with all relevant laws and/or regulations in force in the country or countries concerned.



ARKEMA
420 rue d'Estienne d'Orves
92700 Colombes - France
www.arkema.com

www.forane.com / info.forane@arkema.com